



MMP8 Moisture in Oil Probe
With adjustable installation depth

		Probe type	Probe type	Probe cable	Sensor type	Filter type	Oil coefficients	Baud rate	Parity, data bit, stop bit	Probe Modbus address	Probe mounting accessory	Connection cable
		MMPX	8	A	1							
1	Probe type		8									
		MMP8 with adjustable installation depth										
2	Probe cable			A								
		Probe 8, 2m										
3	Sensor type				1							
		Humicap L2										
4	Filter type					A						
		Stainless steel grid filter										
		Stainless steel grid filter for high flow > 1 m/s				B						
5	Oil coefficients for ppm calculations											
	1)	General purpose mineral oil coefficients					0					
		Midel7131					1					
		FR3					2					
		Dow Corning 561					3					
		Jarylec C101					4					
		Rhodasil					5					
6	Baud rate											
	1)	19200						A				
		9600						B				
7	Parity, data bit, stop bit											
	1)	8,N,2							0			
		8,N,1							1			
		8,E,1							2			
		8,E,2							3			
		8,O,1							4			
		8,O,2							5			
8	Probe Modbus address											
	1)	240								A		
		110								B		
		120								C		
		130								D		
		140								E		
9	Reserved											
		None										0
10	Probe mounting accessory											
		Fitting body NPT1/2"									item: 212810	C
		Fitting body ISO1/2"									item: DRW212076	D
		Ball Valve installation kit, with welding joint									item: BALLVALVE-1	A
		Set: Ballvalve installation kit + NPT1/2" + ISO1/2" fitting bodies									item: BALLVALVE-1SET	E
		Fitting body set ISO 1/2" + NPT 1/2"									item: DRW212076, 212810	F
11	Connection cable											
		None										0
		1,5m, open ends									item: 223263	1
		10m, open ends									item: 216546	2

1) Factory pre-set, can be changed in the field with a service cable (P/N 242659)

Probe can be connected to INDIGO series of transmitters regardless of the output configuration.

Selections in bold are included in the prices of the basic versions.

Selections in *italic* are available at an extra price.

Example of order code with typical settings:

For use with INDIGO transmitters	MMPX	8	A	1	A	0	A	0	A	0	C	0
For Modbus RTU use	MMPX	8	A	1	A	0	A	0	A	0	C	2

Valid from: December 2019